

JUL 20 1973

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

27740

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Clayton

2. LOCATION - 1/4 Section NW Section 34 Township 10 N Range 3 W

3. OWNER AT TIME OF DRILLING Robert Gore Jr.  
ADDRESS R7D  
POST OFFICE Says Mills, Wis. 54631

4. Distance in feet from well to nearest:  
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>40'</u>	<u>48'</u>					

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	<u>50'</u>	<u>80'</u>	<u>85'</u>		<u>200'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>blue limestone</u>	<u>10</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>40</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>Cement</u>	<u>10</u>	<u>40</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 6-23-1973

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Depth from surface to normal water level 42 ft.

Depth to water level when pumping 44 ft.

Well is terminated 20 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-16-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis 53805  
R3 Box 84

COLIFORM TEST RESULT 879 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71