

FEB 14 1985

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Scott	
2. LOCATION 1/4 Section or Gov't. Lot NW		Section 24	Township 9N	Range 3W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Scott Devenny
OR - Grid or Street No. Street or Road Name		ADDRESS Rt. 1			
AND - If available subdivision name, lot & block No.		POST OFFICE Muscoda, Wis		ZIP CODE	
4. Distance in feet from well to nearest: (Record answer in appropriate block) 10		Building Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Floor Drain Connected To: C.I. Sewer Other Sewer		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
Sewage Sump C.I. Other		Clearwater Sump		Septic Tank Holding Tank	
Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		Manure Hopper or Retention or Pneumatic Tank		25	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard	
Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit	
Earthen Silage Storage Trench Or Pit		Earthen Manure Basin			
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls	
Other (Describe)					
5. Well is intended to supply water for: Dwelling			9. FORMATIONS		
			Kind From (ft.) To (ft.)		
6. DRILLHOLE			Topsoil Surface 1		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			Clay 1 15		
10 Surface 46 6 46 130			Shale 15 130		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification					
Dia. (in.) Mfg. & Method of Assembly From (ft.) To (ft.)					
6 Sced 40 18:97 P. Surface 46					
Pitless					
Astm-A-53					
20-1-NKK					
DX 280 W ERWA					
TSE Products					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
Backfill W/ native soil Surface 8			<input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
cement grout 8 46			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
			Well construction completed on Jan 28 1985		
11. MISCELLANEOUS DATA			Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: 5 Hrs. at 8 GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level 61 Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping 71 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to State laboratory on Jan 28 1985					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Albin Herbeck #482			Business Name and Complete Mailing Address Box 186 Richland Center, Wis 53581		
Registered Well Driller					