

1. COUNTY Crawford CHECK ONE Town Village City NAME Gays Mills, Wis.

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Lot 21 Town and block 10 SE 1/4 SW 1/4 Sec 21 T10N, R4W

3. OWNER AT TIME OF DRILLING Ella Bown

4. OWNER'S COMPLETE MAIL ADDRESS Gays Mills, Wis. 54631

5. Distance in feet from well to nearest:

(Record answer in appropriate block)	BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C. I.	TILE	C. I.	TILE	SEWER CONNECTED INDEPENDENT
	8'				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PFT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		75'						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Private home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	50	6	50	100	Clay	Surface	13
						limestone	13	60
						sandstone	60	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	black-plain end new 19.18	Surface	50

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	30
Cement	30	50

11. MISCELLANEOUS DATA			
Yield test:	5 Hrs. at	10 GPM	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	65	ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	65	ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <u>Madison, Wis.</u>			laboratory on: <u>3-18-</u> 19 <u>68</u>

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE	COMPLETE MAIL ADDRESS
<u>Kenneth Coplan</u> Registered Well Driller	<u>53805 R3 Box 84 Boscobel, Wis.</u>

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
918				