

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

13 1978

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Utica

2. LOCATION SW 29 10 N 4 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Rose Marie Lester

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Says Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 80'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	140	6	140	225	top soil	Surface	0 7
						soft shalestone	7	125
						hard shalestone	125	190
						hard sandstone	190	225

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor	0 Surface	140

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	7
Cement	7	140

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 5-16-1978

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 180 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 192 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-6-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boacobel, Wis. R3 Box 84 53805

937