

1. COUNTY Crowford CHECK ONE Town Village City Heenan
 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
pt. Sec 5-TSP10-R.N.S-W-7-NE 1/4, SE 1/4, SW 1/4, NE 1/4, SW 1/4, NW 1/4

3. OWNER AT TIME OF DRILLING Sutherland Bible Camp
 4. OWNER'S COMPLETE MAIL ADDRESS Resortwise

5. Distance in feet from well to nearest: BUILDING C.I. TILE SANITARY SEWER C.I. TILE FLOOR DRAIN C.I. TILE FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE
 (Record answer in appropriate block) 40

CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
The disposal system will be put in later according to State Regulations

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
This place is being rebuilt. Therefore at this time no answers above

6. Well is intended to supply water for: Bible Camp

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
8"	Surface	38	4"	38	205	Clay + Sand mixture	Surface	25-	
						Sandstone	25-	205	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
4"	Steel Blk T & V Well	Surface	38

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Cement	Surface	38

11. MISCELLANEOUS DATA
 Well construction completed on 5/15 1970
 Well is terminated 12 inches above below final grade
 Depth from surface to normal water level 45 ft. Well disinfected upon completion Yes No
 Depth to water level when pumping 90 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 5/21 1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE [Signature] Registered Well Driller COMPLETE MAIL ADDRESS New Alb. Iowa Box 55
 Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
948				