

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

OCT 14 1975

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Utica

2. LOCATION - 1/4 Section NE Section 16 Township 10M Range 5W 3. OWNER AT TIME OF DRILLING Fred H. Eick  
OR - Grid or street no. Street name ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN  
(Record answer in appropriate block) 25' C. I. 50' TILE 50' C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE  
C. I. TILE 125' 130'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>163</u>	<u>6</u>	<u>163</u>	<u>320</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>
						<u>limestone with clay pockets</u>	<u>10</u>	<u>150</u>
						<u>hard sandstone</u>	<u>150</u>	<u>320</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>163</u>

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
puddled clay Surface 10  
Cement 10 163

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with Air  Water

Well construction completed on 9-30-1975

11. MISCELLANEOUS DATA  
Yield test: 3 Hrs. at 5 GPM  
Well is terminated 10 inches  above  below final grade  
Depth from surface to normal water level 210 ft. Well disinfected upon completion  Yes  No  
Depth to water level when pumping 240 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 10-9-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

COLIFORM TEST RESULT 9104 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS  
REV. 3-71