

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Utica

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Sec 22 - TSP-10, R5 - pt NW 1/4 S16 1/4 T41N R17W

3. OWNER AT TIME OF DRILLING RSW Bruce Anderson

4. OWNER'S COMPLETE MAIL ADDRESS Rockford Ill

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
50							

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
			100						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Trailer Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
8	Surface	10	4"	10	102	Clay	Surface	10	
						Gravel	10	26	
						Sandstone	26	102	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
4"	BLP New Set T+C - 11"	Surface	36

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Cement	Surface	10

11. MISCELLANEOUS DATA

Well construction completed on 5/12 1971

Yield test: 8 Hrs. at 10 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 45 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 55 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 5/17 1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE E. W. Meyer Registered Well Driller COMPLETE MAIL ADDRESS New Orleans Louisiana

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
970				