

001 28 1978

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Freeman	
2. LOCATION 1/4 Section NE Section 22 Township 10 N Range 5 W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Douglas E. Mickelson		ADDRESS RR1	
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.		POST OFFICE Ferrisville, WI 54628	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 30'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to Sewer Sewage Sump Clearwater Dr.	
		Sewage Sump C.I. Other		Clearwater Sump	
		Septic Tank		Holding Tank	
		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		90'	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: Country home		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.)	To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	86	6	86	120
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly		From (ft.)		To (ft.)	
Dia. (in.)					
6	new black steel P.E. 18.97 A-53	Surface	86		
	Valley Steel				
	Pitless adaptor				
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)	To (ft.)
		Clay		Surface	8
		Cement		8	86
10. TYPE OF DRILLING MACHINE USED		Well construction completed on 9-14-1978			
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade			
Yield Test: 2 Hrs. at 5 GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level 90 Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping 98 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Water sample sent to Madison laboratory on 10-10-1978			
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Copion Registered Well Driller			Complete Mail Address Boscobel, WI R3 Box 84 53805		

971