

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
See Instructions on Reverse Side

1. County Crawford Town  Seneca  
 Village   
 City  Check one and give name

2. Location 7 miles N. of Seneca SECTION 5W  
 Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Herbert Guamme  
 Name of individual, partnership or firm

4. Mail Address Ferryville, Wis. R. F. D.  
 Complete address required

5. From well to nearest: Building 15 ft; sewer 0 ft; drain 0 ft; septic tank 0 ft;  
 dry well or filter bed 0 ft; abandoned well 0 ft.

6. Well is intended to supply water for: farm and home

**7. DRILLHOLE:**

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	40			

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard wt	0	40

**RECEIVED**  
APR 16 1957

**9. GROUT: ENVIRONMENTAL**

Kind	From (ft.)	To (ft.)
Cement + clay	0	40

**11. MISCELLANEOUS DATA:**

Yield test: 15 Hrs. at 10 GPM.  
 Depth from surface to water-level: 200 ft.  
 Water-level when pumping: 205 ft.  
 Water sample was sent to the state laboratory at:  
Madison on Apr. 9 1957  
 City

**10. FORMATIONS:**

Kind	From (ft.)	To (ft.)
<u>This is an old well which I repaired therefore I cannot give you information on formations. I recased and drilled 40 ft. deeper.</u>		

Construction of the well was completed on:  
April 1 1957

The well is terminated 6 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No

Was the well sealed watertight upon completion?  
 Yes  No

Signature Kenneth Coyne  
 Registered Well Driller

R. 3 Box 36, Boacobel  
 Complete Mail Address

Please do not write in space below

Rec'd APR 10 1957 No. 8944

Ans'd **SAFE**  
 Interpretation

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coli 0

**WGNHS ORIGINAL**

Examiner \_\_\_\_\_