

DEC 18 1973

1. COUNTY Krawford CHECK ONE Town Village City NAME Seneca

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
N. 1/4, 1/4 SW, 1/4 Sec 31 Twp 10N, R 5W

3. OWNER AT TIME OF DRILLING Herold Volk

4. OWNER'S COMPLETE MAIL ADDRESS Seneca Iowa R-

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C. I.	TILE	C. I.	TILE
			SEWER CONNECTED	INDEPENDENT

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	230	6"	230	517	Drift	Surface	60	
						Lime	60	203	
						Sandstone	203	517	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	White Steel 19.45#	Surface	230

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Cement	Surface	230

11. MISCELLANEOUS DATA

Well construction completed on 12/5 1973

Yield test: 20 hrs Hrs. at 15 GPM Well is terminated 18 inches above below final grade

Depth from surface to normal water level 354 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 450 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 12/12 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Edwin W. Meyer Registered Well Driller COMPLETE MAIL ADDRESS Seneca Iowa, Box 55

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
----------------------	---------------	---------------	-----------	---------