

AUG 30 1979

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOTE:

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION NW Section 5 Township 10N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
ADDRESS Carlyle A. Hanson
R R 1

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, Wis., 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 90'
Sewage Sump Clearwater Sump C.I. Other Sewage Sump Clearwater Sump Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	64	6	64	140

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & stone	Surface	30
hard shale stone	30	90
sandstone	90	140

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97	0	64
	A-53		
	Valley Steel		
	Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0	8
Cement	8	64

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Well construction completed on 8-16-1979

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 70 Ft.

Well disinfected upon completion Yes No

Depth of water level when pumping 78 Ft. Stabilized Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-27-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan
998
Registered Well Driller

Complete Mail Address Boscobel, Wis., R2 Box 4 53805